



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Portland Metropolitan Workforce Training Center

Building	Level	Location	Source Type	Sample Date	Lead Results (ppb)
1	1	Hall Across From Room 110	Drinking Fountain (Left)	9/2/2016	14
2	1	Outside of Room 106	Sink	9/2/2016	3.6
2	2	Room 202	Sink	9/2/2016	24

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document, entitled *3Ts for Reducing Lead in Drinking Water in Schools*. First draw samples were collected and laboratory analysis indicates that all but one of the water samples collected contained lead at concentrations below the EPA action level of 20 ppb. The water source, from which the sample with a lead concentration > 20 ppb was collected, has been shut off and signs have been posted to alert building occupants of alternate drinking water sources.

ppb = parts per billion (20 ppb = 0.020 mg/L)