



TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Rock Creek Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
1	1	Men’s restroom	Sink on the left	8/22/2018	ND
2	1	North Women’s restroom	Sink on the left	8/22/2018	ND
2	2	Near Room 226	Bottle Fill Station	8/22/2018	ND
3	1	Women’s restroom near Room 114	Sink (third)	8/22/2018	2
3	2	Women’s restroom	Sink on the left	8/22/2018	ND
4	1	Men’s restroom	Sink	8/22/2018	ND
5	1	In gym near Women’s locker room	Drinking fountain	8/22/2018	ND
5	1	Dining services food prep area	Sink just inside door from main service area	8/22/2018	ND
5	2	Between restrooms	Bottle fill station	8/22/2018	ND
6	1	Women’s restroom in N. Hanger	Sink on the left	8/22/2018	ND
7	1	Men’s restroom	Sink on the right	8/22/2018	8
7	2	Across from Room 214	Bottle Fill Station	8/22/2018	ND
9	1	Women’s restroom	Sink third from the left	8/22/2018	ND
9	2	Men’s restroom	Sink on the right	8/22/2018	ND
Farmhouse	1	Guest bathroom	Sink	8/22/2018	3
Farm Shop	1	Main Shop	Sink	8/22/2018	2
Kennel	1	All gender restroom	Sink	8/22/2018	2

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools.*

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
 ND = Non-Detect