



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Southeast Campus

| Building | Level | Location | Source Type | Sample Date | Lead Result (ppb) |
|-----------------|-------|----------------------------------|--------------------------------|-------------|-------------------|
| Admin | 1 | All gender restroom on the right | Sink | 8/23/2018 | ND |
| Admin | 2 | Room 207 break room | Sink | 8/23/2018 | ND |
| Admin | 3 | All gender restroom | Sink | 8/23/2018 | 6 |
| Admin | 4 | Room 410 break room | Sink | 8/23/2018 | ND |
| Annex | 1 | Room 79 break room | Sink | 8/23/2018 | ND |
| Library | 1 | Men's restroom | Sink on the right | 8/23/2018 | ND |
| Library | 2 | Men's restroom | Sink on the right | 8/23/2018 | ND |
| Library | 3 | Room 301 southeast corner | Drinking fountain | 8/23/2018 | ND |
| Mt. Scott Hall | 1 | Men's restroom | Sink on the left | 8/23/2018 | ND |
| Mt. Scott Hall | 2 | Women's restroom | Sink on the right | 8/23/2018 | ND |
| Mt. Tabor Hall | 1 | Dining services main area | Sink beside griddle and drinks | 8/23/2018 | ND |
| Mt. Tabor Hall | 1 | Near restrooms on the north end | Drinking fountain (short) | 8/23/2018 | ND |
| Student Commons | 1 | Women's restroom | Sink on the left | 8/23/2018 | ND |
| Student Commons | 2 | Near Room 214 | Bottle fill station | 8/23/2018 | ND |
| Student Commons | 3 | Men's restroom | Sink in the middle | 8/23/2018 | ND |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
ND = Non-Detect