



Environmental Health & Safety District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
AM	1	Men's Restroom	Sink	1/15/21	1.00
AM	1	Women's Restroom	Sink	1/15/21	0.839
AM	1	Outside Room 115 A	Bottle Fill Station	1/15/21	2.59
AM	2	Men's Restroom	Sink	1/15/21	1.04
AM	2	Women's Restroom	Sink	1/15/21	3.76
AM	2	Outside Room 206	Bottle Fill Station	1/15/21	5.49
BK	1	Near Elevator	Drinking Fountain	1/15/21	5.72
BK	2	Room 107 Break Room	Sink	1/15/21	1.84
CSB	1	Room 109 Break Room	Sink	1/15/21	0.955
CSB	2	Room Break Area	Sink	1/15/21	0.446
CSB	3	Room 305 Break Room	Sink	1/15/21	0.368
HT	2	River City Annex	Sink	1/15/21	11.5
HT	3	Room 312E Break Room	Sink	1/15/21	19.8
HP	13	Room Break Room	Sink	1/15/21	4.37

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicated that one (1) water sample collected contained lead at a concentration that was above the EH&S watch level of 15 ppb. This was: HT 3rd floor Room 312E Breakroom sink at 19.8 ppb.

The faucet was replaced, and water lines flushed for an extended period for that location.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)