



**Environmental Health & Safety**  
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Sylvania Campus**

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
HT	1	Room 122 Break Room	Sink	3/12/2021	4.17
HT	1	Women's Restroom	Right Sink	3/12/2021	3.23
HT	1	Men's Restroom	Second Sink from Right	3/12/2021	6.72
HT	3	Room 312E Break Room	Sink	3/12/2021	3.69
<b>HT</b>	<b>3</b>	<b>Room 302A Break Room</b>	<b>Sink</b>	<b>3/12/2021</b>	<b>23.5</b>

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document titled: *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicated that one (1) water sample collected contained lead at concentrations that was above the EPA action level of 20 ppb. That was: HT 3<sup>rd</sup> floor Room 302A Break area sink at 23.5 ppb.

Faucet components were replaced, and the line were flushed for an extended period of time.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)