



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Climb Center

Level	Location	Source Type	Sample Date	Lead Result (ppb)
1	Outside Restrooms	Bottle Fill Station	8/10/2021	ND
1	Women's Restroom	Sink	8/10/2021	5.88
1	Room 101 Break area	Sink	8/10/2021	3.59
2	Outside Restrooms	Bottle Fill Station	8/10/2021	ND
2	Men's Restroom	Sink	8/10/2021	2.45
3	Outside Restrooms	Bottle Fill Station	8/10/2021	ND
3	Women's Restroom	Sink	8/10/2021	2.26

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
ND = none detected