



**Environmental Health & Safety**  
District Water Quality

Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Downtown Center**

Level	Location	Source Type	Sample Date	Copper Results (mg/L)	Lead Result (ppb)
B	East Gender Neutral Restroom	Sink	8/17/2017	0.388	ND
1	Room 109	Sink	8/17/2017	0.156	ND
2	Breakroom 208	Refrigerator Water Dispenser	8/17/2017	0.168	ND
3	Men's Restroom	Sink	8/17/2017	0.277	ND
4	Breakroom 409	Refrigerator Water Dispenser	8/17/2017	ND	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)  
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)