



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Columbia County Center (OMIC)

| Level | Location | Source Type | Sample Date | Lead Result (ppb) |
|-------|-------------------------|---------------------|-------------|-------------------|
| 1 | Room 115D Break area | Sink | 8/11/2021 | 2.05 |
| 1 | Vending/Break area | Sink | 8/11/2021 | 2.61 |
| 1 | Room 117 Wellness | Sink | 8/11/2021 | 2.93 |
| 1 | Right All User Restroom | Sink | 8/11/2021 | 1.79 |
| 1 | Left All User Restroom | Sink | 8/11/2021 | 1.87 |
| 1 | Men's Restroom | Sink | 8/11/2021 | 2.15 |
| 1 | Women's Restroom | Sink | 8/11/2021 | 3.80 |
| 1 | Outside Restrooms | Bottle Fill Station | 8/11/2021 | ND |
| 1 | Shop Floor | Bottle Fill Station | 8/11/2021 | 0.200 |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
ND = none detected