



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Southeast Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
CHAX	1	Room 146 Break area	Sink	8/12/2021	0.354
CHAX	1	Women’s Restroom near Comm Hall	Sink	8/12/2021	0.580
CHAX	1	Men’s Restroom near Comm Hall	Sink	8/12/2021	0.755
LIB	1	Outside Restrooms	Bottle Fill Station	8/12/2021	ND
LIB	1	Women’s Restroom	Sink	8/12/2021	1.23
LIB	1	Room 116 Break area	Sink	8/12/2021	0.235
MSH	1	Women’s Restroom	Sink	8/12/2021	2.86
MSH	1	Outside Restrooms	Drinking Fountain	8/12/2021	5.42
MSH	2	Men’s Restroom	Sink	8/12/2021	3.42
MSH	2	Outside Restrooms	Drinking Fountain	8/12/2021	0.896
MTH	1	Women’s Restroom near Room 102	Sink	8/12/2021	2.02
MTH	1	Outside Room 102	Bottle Fill Station	8/12/2021	5.95
MTH	1	Men’s Restroom near Dining Services	Sink	8/12/2021	7.25
MTH	1	Beside Vending Area	Bottle Fill Station	8/12/2021	0.328
MTH	1	Women’s Restroom near Room 141	Sink	8/12/2021	16.1
MTH	1	Outside Restrooms near Room 141	Drinking Fountain	8/12/2021	1.5
SCOM	1	Room 116Q Break area	Sink	8/12/2021	2.64
SCOM	1	Men’s Restroom	Sink	8/12/2021	1.24
SCOM	1	Outside Restrooms	Bottle Fill Station	8/12/2021	ND
SCOM	2	Near Vending Machines	Bottle Fill Station	8/12/2021	0.352
SCOM	2	Women’s Restroom	Sink	8/12/2021	1.22
SCOM	2	Room 225 Break area	Sink	8/12/2021	1.48
SCOM	2	Near Room 213	Bottle Fill Station	8/12/2021	ND
SCOM	3	Near Room 314	Bottle Fill Station	8/12/2021	ND
SCOM	3	Women’s Restroom	Sink	8/12/2021	1.88
SCOM	3	Near Vending Machines	Bottle Fill Station	8/12/2021	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
 ND = None detected