



**Environmental Health & Safety**  
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Southeast Campus**

Building	Level	Location	Source Type	Sample Date	Copper Results (mg/L)	Lead Result (ppb)
Admin	1	Women’s Restroom	Sink	6/6/2019	0.587	0.756
Admin	2	Room 202 Restroom	Sink	6/6/2019	1.13	2.02
Admin	3	Room 309 Break Area	Sink	6/6/2019	0.989	1.92
Annex	1	Room 139 Kitchen Prep	Sink	6/6/2019	0.184	1.00
Library	1	Men’s Restroom	Sink (Center)	6/6/2019	0.155	0.311
Library	2	Near North Stairs	Drinking Fountain (Short)	6/6/2019	0.125	ND
Library	3	Gender Neutral Restroom	Sink	6/6/2019	0.0906	0.719
Mt. Scott Hall	1	Near Room 100	Drinking Fountain (Tall)	6/6/2019	0.269	ND
Mt. Scott Hall	2	Near Room 200	Drinking Fountain (Short)	6/6/2019	0.202	ND
Mt. Tabor Hall	1	Dining Services – Coffee Area	Sink	6/6/2019	0.168	ND
Mt. Tabor Hall	1	Near Room 101	Drinking Fountain	6/6/2019	0.401	0.566
Student Commons	1	Men’s Restroom	Sink (Right)	6/6/2019	0.0717	0.361
Student Commons	2	Room 225 Breakroom	Sink	6/6/2019	0.0721	0.243
Student Commons	3	Women’s Restroom	Sink (Left)	6/6/2019	0.0574	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)  
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)