Compressed Gas Safety Plan – Form 1: Inspection Checklist

Department: _____

Date: _____

Location: _____

| Inspection (| Completed | by:_ |
|--------------|-----------|------|
|--------------|-----------|------|

| Description | Yes | No | N/A | Comments |
|---|-----|----|-----|----------|
| Emergency Preparedness | -1 | r | 1 | |
| Emergency Guide posted | | | | |
| Fire Extinguishers mounted, accessible, inspected | | | | |
| First aid kits available nearby and well stocked | | | | |
| Spill kits present and with appropriate material | | | | |
| Fire blankets accessible | | | | |
| Emergency map with evacuation routes posted | | | | |
| Leak detection equipment is working properly | | | | |
| Equipment | | | | |
| Cylinders are not dented, corroded, or damaged | | | | |
| Labels/markings are intact and legible | | | | |
| Hoses and fittings are not dented, bulging, or in other ways damaged | | | | |
| Regulators and valves are clean and working properly | | | | |
| Appropriate personal protective equipment available in | | | | |
| sufficient quantities and in good condition | | | | |
| Storage | -1 | r | 1 | |
| Cylinders are securely strapped or chained to prevent falling | | | | |
| When not in use, regulators are disconnected and valve caps are securely in place | | | | |
| Emergency equipment isn't blocked | | | | |
| Cylinders are stored away from localized heat sources | | | | |
| Material handling equipment for moving tanks is available | | | | |
| and not damaged | | | | |
| Proper separation is maintained between incompatible gases | | | | |
| • Empty and full cylinders are stored separately | | | | |
| Other Issues Noted: | | | | |