



**Environmental Health & Safety**  
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Cascade Campus**

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
CH	1	Room 102	Sink	6/17/22	0.347
CH	2	Outside Restrooms	Bottle Fill Station	6/17/22	ND
CH	3	Outside Restrooms	Bottle Fill Station	6/17/22	ND
JH	2	Room 208 Break Area	Sink	6/17/22	5.03
LIB	1	Room 120 Breakroom	Sink	6/17/22	0.219
LIB	2	Outside Restrooms	Drinking Fountain	6/17/22	ND
LIB	3	Near Elevator	Drinking Fountain	6/17/22	3.88
MAHB	1	Room 105 Breakroom	Sink	6/17/22	2.36
MAHB	2	Outside Room 220	Drinking Fountain	6/17/22	0.310
Paragon	1	Room 107	Left Sink	6/17/22	0.316
PEB	1	Main Lobby	Bottle Fill Station	6/17/22	0.262
PEB	2	Near Elevator	Drinking Fountain	6/17/22	0.542
PS	1	Kitchen	Sink	6/17/22	0.488
PSEB	1	Vending Break Area	Sink	6/17/22	2.54
SSB	1	Room 103 Breakroom	Sink	6/17/22	0.442
SSB	2	Near Room 201	Drinking Fountain	6/17/22	0.268
SSB	3	Outside Restrooms	Drinking Fountain	6/17/22	3.28
SU	1	Outside Restrooms	Bottle Fill Station	6/17/22	ND
SU	1	Dinking Services Kitchen	Prep Sink	6/17/22	14.6
SU	2	Room 206 Break Area	Sink	6/17/22	1.75
SU	3	Room 309	Sink	6/17/22	3.16
TEB	1	Room 102	Sink	6/17/22	1.28
TEB	2	Outside Room 222	Drinking Fountain	6/17/22	ND
TH	1	Near North Stairwell	Drinking Fountain	6/17/22	0.609
TH	2	Room 220B	Sink	6/17/22	6.17

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)