



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Rock Creek Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
1	1	Room 112 Breakroom	Sink	6/16/22	0.297
2	1	Near Room 113	Bottle Fill Station	6/16/22	ND
2	2	Room 237 Breakroom	Sink	6/16/22	4.40
3	1	Main Lobby	Drinking Fountain	6/16/22	ND
3	2	Room 203 Breakroom	Sink	6/16/22	0.718
4	1	Room 104	Sink	6/16/22	2.65
5	1	Outside Restrooms	Bottle Fill Station	6/16/22	ND
5	1	Dining Services Kitchen	Sink	6/16/22	0.405
5	2	Room 264 Breakroom	Sink	6/16/22	ND
6	1	Outside Restrooms	Bottle Fill Station	6/16/22	ND
7	1	Outside Room 116	Bottle Fill Station	6/16/22	ND
7	2	Room 202 Breakroom	Sink	6/16/22	5.59
9	1	Room 114 Breakroom	Sink	6/16/22	2.19
9	2	Outside Restrooms	Drinking Fountain	6/16/22	0.359
Kennel	1	Room 104	Sink	6/16/22	0.666
Grounds	1	Breakroom	Sink	6/16/22	1.08
Farmhouse	1	Kitchen	Sink	6/16/22	0.210

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)