



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Southeast Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
ADM	1	Outside Restrooms	Bottle Fill Station	6/17/22	ND
ADM	2	Room 207 Breakroom	Sink	6/17/22	3.79
ADM	3	Room 309 Breakroom	Sink	6/17/22	2.14
ADM	4	Room 410 Breakroom	Sink	6/17/22	1.20
CHAX	1	Room 79 Breakroom	Sink	6/17/22	0.554
LIB	1	Room 116 Break Area	Sink	6/17/22	1.25
LIB	2	Near East Stairwell	Bottle Fill Station	6/17/22	0.222
LIB	3	Outside Restrooms	Bottle Fill Station	6/17/22	0.229
MSH	1	Outside Restrooms	Drinking Fountain	6/17/22	0.488
MSH	2	Outside Room 200	Drinking Fountain	6/17/22	0.423
MTH	1	Dining Services – Kitchen	Prep Sink	6/17/22	ND
MTH	1	Near Room 141	Drinking Fountain	6/17/22	0.623
SCOM	1	Room 116 Breakroom	Sink	6/17/22	0.430
SCOM	2	Room 225 Breakroom	Sink	6/17/22	ND
SCOM	3	Near Vending Machines	Bottle Fill Station	6/17/22	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)