



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Cascade Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
CH	1	Outside Restrooms	Bottle Fill Station	6/15/23	ND
CH	2	Gender Neutral Restroom	Sink	6/15/23	0.242
CH	3	Women’s Restroom	Sink	6/15/23	0.224
JH	1	Outside Restrooms	Bottle Fill Station	6/15/23	ND
JH	2	Gender Neutral Restroom	Sink	6/15/23	0.857
LIB	1	Outside Restrooms	Bottle Fill Station	6/15/23	ND
LIB	2	Gender Neutral Restroom	Sink	6/15/23	0.344
LIB	3	Near Elevator	Drinking Fountain	6/15/23	4.480
MAHB	1	Room 105 Breakroom	Sink	6/15/23	4.060
MAHB	2	Outside Room 220	Drinking Fountain	6/15/23	ND
Paragon	1	South Restroom	Sink	6/15/23	0.268
PEB	1	Men’s Restroom	Sink	6/15/23	1.820
PEB	2	Women’s Restroom	Sink	6/15/23	3.900
PS	1	Kitchen	Sink	6/15/23	ND
PSEB	1	Outside Room 110	Bottle Fill Station	6/15/23	ND
SSB	1	Room 103 Breakroom	Sink	6/15/23	0.288
SSB	2	Men’s Restroom	Sink	6/15/23	0.938
SSB	3	Outside Restrooms	Drinking Fountain	6/15/23	0.834
SU	1	Outside Restrooms	Bottle Fill Station	6/15/23	ND
SU	1	Dinking Services Kitchen	Prep Sink	6/15/23	7.980
SU	2	Room 206 Break Area	Sink	6/15/23	0.240
SU	3	Gender Neutral Restroom	Sink	6/15/23	5.660
TEB	1	Room 102	Sink	6/15/23	0.963
TEB	2	Men’s Restroom	Sink	6/15/23	0.368
TH	1	Room 109C	Sink	6/15/23	0.233
TH	2	Outside Restrooms	Bottle Fill Station	6/15/23	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools.*

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 15 ppb.

ppb = parts per billion (i.e., 15 ppb = 0.015 µg/L)