



**Environmental Health & Safety**  
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Hillsboro Center**

Level	Location	Source Type	Sample Date	Lead Result (ppb)
1	Near Room 114	Drinking Fountain	6/14/23	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 15 ppb.

ppb = parts per billion (i.e., 15 ppb = 0.015 µg/L)