



**Environmental Health & Safety**  
**District Water Quality Sampling**

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Sylvania Campus**

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
AM	1	Room 101 Gender Neutral Restroom	Sink	6/13/23	0.659
AM	2	Outside Room 216	Drinking Fountain	6/13/23	3.560
BK	G	Restroom	Sink	6/13/23	4.380
BK	1	Outside Restrooms	Bottle Fill Station	6/13/23	ND
BK	2	Outside Elevator	Drinking Fountain	6/13/23	0.733
CC	1	Room 116E Break Area	Sink	6/13/23	ND
CC	2	Room 234H Breakroom	Sink	6/13/23	0.804
CC	2	Dining Services – River City	Prep Sink	6/13/23	0.575
CSB	1	Gender Neutral Restroom	Sink	6/13/23	1.220
CSB	2	Near Room 205	Bottle Fill Station	6/13/23	ND
CSB	3	Outside Restrooms	Drinking Fountain	6/13/23	0.736
CT	1	Women’s Restroom	Sink	6/13/23	ND
CT	2	Men’s Restroom	Sink	6/13/23	ND
HP	1	Room 106 Break Area	Sink	6/13/23	0.864
HP	2	Room 202A	Sink	6/13/23	2.240
HT	G	Room 05 Breakroom	Sink	6/13/23	ND
HT	1	Men’s Locker Room	Drinking Fountain	6/13/23	0.484
HT	2	Gym	Left Bottle Fill Station	6/13/23	0.817
LIB	1	Room 109 Break Area	Sink	6/13/23	1.180
LIB	2	Room 208C Break Area	Sink	6/13/23	1.270
MOD	1	Men’s Restroom	Sink	6/13/23	0.622
PAC	1	Room 106	Sink	6/13/23	2.930
SS	2	Room 201R Breakroom	Sink	6/13/23	0.453
ST	2	Outside Room 215	Drinking Fountain	6/13/23	ND
ST	3	Room 312C Breakroom	Sink	6/13/23	7.680
TCB	1	Room 115C Breakroom	Sink	6/13/23	3.840
TCB	2	Men’s Restroom	Sink	6/13/23	ND
TCB	3	Outside Restrooms	Bottle Fill Station	6/13/23	0.502

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 15 ppb.

ppb = parts per billion (i.e., 15 ppb = 0.015 µg/L)