



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Child Development Center

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
Main	1	Room 106 Lactation	Sink	6/13/23	2.940
Main	1	Room 107	Sink	6/13/23	ND
Main	1	Room 108	Sink (Right)	6/13/23	1.050
Main	1	Room 108	Sink (Left)	6/13/23	0.748
Main	1	Room 110	Sink	6/13/23	ND
Main	1	Restroom (Right)	Sink	6/13/23	ND
Main	1	Restroom (Left)	Sink	6/13/23	ND
Main	1	Near Room 116	Bottle Fill Station	6/13/23	ND
Main	1	Laundry Room	Sink	6/13/23	ND
Main	1	Room 115 Kitchen	Sink (Right)	6/13/23	ND
Main	1	Room 115 Kitchen	Sink (Left)	6/13/23	ND
Main	2	Break Area	Sink	6/13/23	ND
Main	2	Gender Neutral Restroom (Left)	Sink	6/13/23	ND
Main	2	Gender Neutral Restroom (Right)	Sink	6/13/23	ND
Bldg 2	1	Room 117	Sink (Tall)	6/13/23	0.780
Bldg 2	1	Room 117	Sink (Short)	6/13/23	0.430
Bldg 2	1	Room 118	Sink	7/18/23	0.665
Bldg 2	1	Room 119	Sink – Northeast	6/13/23	0.875
Bldg 2	1	Room 119	Sink – Southeast	6/13/23	0.393
Bldg 2	1	Room 119	Sink – Southwest	6/13/23	0.459
Bldg 2	1	Room 119	Sink – Northwest	6/13/23	0.631
Bldg 2	1	Room 120	Sink (Tall)	6/13/23	0.254
Bldg 2	1	Room 120	Sink (Short)	6/13/23	0.488
Bldg 3	1	Room 121	Sink (Tall)	6/13/23	1.020
Bldg 3	1	Room 121	Sink (Short)	6/13/23	0.331
Bldg 3	1	Room 122a	Sink (Tall - South)	6/13/23	0.222
Bldg 3	1	Room 122a	Sink (Short - South)	6/13/23	0.473
Bldg 3	1	Room 122b	Sink (Tall - North)	6/13/23	ND
Bldg 3	1	Room 122b	Sink (Short - North)	6/13/23	0.328
Bldg 3	1	Room 124	Sink (Tall)	6/13/23	1.110
Bldg 3	1	Room 124	Sink (Short)	6/13/23	0.299

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 15 ppb.

ppb = parts per billion (i.e., 15 ppb = 0.015 µg/L)